



DELHI JAL BOARD
(GOVT. OF N.C.T. DELHI)
QUALITY CONTROL LABORATORY,
WATER TREATMENT PLANT NANGLOI, DELHI-110041



Water Samples collected from "Hari Krishna Public School", A-114-118, Mansa Ram Park, Uttam Nagar, New Delhi - 110059 Vide Challan No. 173 Dt - 28.10.2024.

**THE TEST REPORT IS
FOR THIS PARTICULAR
WATER SAMPLE ONLY.**

S1: DJB Supply at above site

S2: Drinking Point at above site.

S1: DJB Supply at above site		FOR THIS PART ONLY. WATER SAMPLE ONLY.			S1	S2
S. No.	Particulars	Units	Limit		S1	S2
			Acceptable	Permissible		
PHYSICAL EXAMINATION						
1.	Date of collection	-----	--	--	14.11.24	14.11.24
2.	Date of Analysis	-----	--	--	16.11.24	16.11.24
3.	Colour	CU	5.0	15	Clear	Clear
4.	Odour	-----	No. Objectionable		No Obj.	No Obj.
5.	Turbidity	N.T.U.	1.0	5.0	1.2	1.1
6.	PH value	-----	6.5	8.5	7.60	7.58
7.	Electrical Conductivity	µmho/cm	--	--	310.6	302.9
8.	Total dissolved solids	mg/l	500	2000	201.9	196.8
CHEMICAL EXAMINATION						
9.	Phenolphthalein Alkalinity	mg/l	--	--	NIL	NIL
10.	Total Alkalinity	mg/l	200	600	96	94
11.	Total Hardness	mg/l	200	600	128	126
12.	Calcium Hardness	mg/l	--	--	74	74
13.	Magnesium Hardness	mg/l	--	--	54	52
14.	Calcium as Ca	mg/l	75	200	29.6	29.6
15.	Magnesium as Mg	mg/l	30	100	12.96	12.48
16.	Ammonia as N	mg/l	0.5	N.R.	NIL	NIL
17.	Nitrite as N	mg/l	---	--	NIL	NIL
18.	Nitrate as No ₃	mg/l	45	N.R.	2.8	2.4
19.	Sulphate	mg/l	200	400	22	20
20.	Chloride	mg/l	250	1000	14	16
21.	Dissolved Iron	mg/l	1	N.R.	0.04	0.04
22.	Fluoride	mg/l	1	1.5	0.26	0.20
23.	Cyanide	mg/l	0.05	N.R.	ND	ND
24.	Residual Chlorine	mg/l	0.20(min)	1.0	0.60	0.40
BACTERIOLOGICAL EXAMINATION						
25.	Coli-form per 100 ml at 37°C	MPN	0		0	0

Asstt. Chief Water Analyst

D.J.B.

Diary No. 524

Date: 26/11/24

Nangloi, Delhi-41

Samples S1 & S2 can be used for drinking purpose.

REMARKS: As per tested parameters, Samples S1 & S2 can be used for drinking purpose.


Asstt. Chief Water Analyst
DELHI JAL BOARD
Govt. of N.C.T. Delhi
Quality Control Laboratory
Water Works Nangloi, Delhi-41

BACT.

A/CHEMIST



MUNICIPAL CORPORATION OF DELHI
OFFICE OF DEPUTY HEALTH OFFICER
NAJAFGARH ZONE



No: DHO/NGZ/MCD/2024/D-1412

Dated 13/12/24

1. Name of the School: - **HARI KRISHNA PUBLIC SCHOOL**
2. SCHOOL ADDRESS – **A-114-118, MANSA RAM PARK UTTAM NAGAR NEW DELHI 110059.**
3. NO. OF SHIFT ONE TIMING 08:00 AM TO 02:00 PM
4. NO. OF STUDENTS: **BOYS -648 GIRLS -503 TOTAL = 1151**
5. NO. OF STAFFS: **MALE- 04 FEMALE -38 TOTAL =42**

Details of Accommodations present in School

- | | |
|--|--|
| 6. Floor Space in the Classroom Sufficient/insufficient | SUFFICIENT |
| 7. The Classrooms are Well Lighted/ill lighted | WELL LIGHTED |
| 8. The Classrooms are Well Ventilated/ill ventilated | WELL VENTILATED |
| 9. The Classrooms are kept / Not kept Neat & Clean: | NEAT AND CLEAN |
| 10. The Building requires/does not required Whitewash etc. | NOT REQUIRED |
| 11. The Drinking Water is Wholesome/Not wholesome | WHOLESOME |
| 12. The Latrine arrangement is Sanitary/Insanitary | SANITARY FROM HEALTH POINT OF VIEW. |

No. of toilets seats for student

13. One latrine-cum-urinal is required for 25 female student, so total is **SUFFICIENT**
14. One latrine for 40 male student is required so total is **SUFFICIENT**
15. Separate Toilet arrangement for staff present: Yes/No **YES SEPARATE EXISTS FOR STAFF.**
16. The Overall facilities: Good/ Adequate/Inadequate **GOOD FROM HEALTH POINT OF VIEW.**

If building Department or any other govt. agency takes actions against u/a construction or any dispute, then the Health Certificate will be stand cancelled /revoked without any further intimation in this regard


Deputy Health Officer
Municipal Corporation of Delhi
Health Deptt., Najafgarh Zone

(Remarks: This Certificate is valid for one year from the date of issue and this has no bearing on any unauthorized construction)